

Town of Lancaster

BUILDING DEPARTMENT

21 CENTRAL AVENUE LANCASTER, NEW YORK 14086 716-684-4171 FAX 685-5317 TOWN BOARD Supervisor Johanna M. Coleman

Councilmembers
John M. Abraham, Jr.
Dawn Gaczewski
Ronald Ruffino, Sr.
Matthew Walter

FLECTRICAL REQUIREMENTS for ABOVE GROUND POOLS

As applicant/recipient of a permit for installation of an above ground pool you are required to follow the electrical requirements as set forth in this communication. Electrical Inspection is mandatory before final inspection by the Town of Lancaster or the pool is put in-use. Accepted Electrical Inspection agencies shall be provided upon request.

1) Pool Pump Receptacle

- a) A receptacle cannot be located within 6 ft. of the pool wall.
- b) A receptacle located from 6 ft. to 10 ft. of the pool wall is required to be a twist lock type with Ground Fault Circuit Interrupter (GFCI) protection.
- c) A receptacle located more than 10ft. from the pool wall; standard straight blade receptacle with Ground Fault Circuit Interrupter (GFCI) is permitted.
- d) Exposed outdoor receptacles must have weather-tight in-use covers.
- e) A separate circuit is required if the pump motor draws more than 50% of the circuit rating.
- f) Receptacle wiring must be type THHN for wet locations run in conduit when installed outdoors. Required conduit materials maybe either PVC buried to a depth of 18 ins. or Rigid Steel buried at a depth of 6 ins. (exception: PVC conduit is permitted at a depth of 12 ins. when the circuits are GFCI protected before entering the ground; the GFCI protection must be located in/on the dwelling, shed or garage.) expansion coupling on the conduit is required at the dwelling, shed or garage.
- g) Ground wire installed in conduit for pump motor shall be not less than #12 AWG insulated wire.
- h) Change over to romex wire **is permitted** by use of a junction box with proper splicing methods at the point of entry to the interior of the dwelling, shed or garage.
- i) UF cable is not permitted for pool pump receptacle installation.

j) Pool Pump cord shall be 3-conductor, not less than #12 AWG, not longer than 3ft. with a twist-lock or straight blade plug as per letter b & c of this section.

2) Convenience Receptacle

- a) Minumium of 1 GFCI protected receptacle is required at a location of not less than 6 ft. or more than 20 ft. from the pool wall.
- b) Receptacle **must be** equipped with a weather-tight in-use cover when exposed to the outdoors.
- c) Receptacle **must be** a separate circuit from the pump motor if the rating of the pump motor exceeds the circuit rating.
- d) Wire type **may be** direct burial UF cable or part of the conduit system installed for the pump motor.

3) Pool Bonding

- a) #8 solid, un-insulated copper; installed 18 ins. to 24 ins. from the pool wall at a depth of 4 ins. to 6 ins. following the perimeter is required.
- b) Bonding of a metal frame pool at 4 equally space points, following the perimeter with approved connectors is required.
- c) Bonding of the pump motor to the installed system is required.
- d) A water bond is required as part of the bonding system per parts a, b & c of this section. A water bond is a concave 9 in. square plate with an approved connection attached to the skimmer basket or a fitting with an approved connection attached to the suction or discharge port of the pool pump.
- e) Any metal object more than 4 ins. measured in any direction penetrating into the metal pool frame more than 1 in. **must be** connected to the bonding system.
- f) Any fixed metal items (fences, down spouts, gutters, aluminum siding, decks, etc.) within 5 ft. of the pool frame **must be** part of the bonding system described in this section.

4) Timer

All pool pump motors are required to be run on a timer. Typical timers are as follows.

- i. Clock style mounted inside a garage, shed or dwelling.
- ii. Weather-tight Clock style mounted outdoors on a garage, shed or dwelling.
- iii. A timer device integral to the motor or motor controller.